

Compliance Statement

No. 2022-758A

Data communication cable, Category 6

Company

DataCom
3rd Floor S-19 Hotel Suites
Al Jaddaf Waterfront, P.O. Box 24120
Dubai
United Arab Emirates

Product description

Unscreened cable (U/UTP) characterised up to 250 MHz Horizontal floor wiring cable, $100~\Omega$ 4 twisted pairs Flame retardant, halogen free

Product identification

DC-CBL-C64P-LSZH Cat 6 UTP 4 pairs 23 AWG Solid Cable LSZH – 305M

Generic cabling and cabling components standards - Category 6 cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-6-1:2013
- TIA-568.2-D:2018

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12233766, DANAK-19/23103

EC Cabling product ID 7157

CS valid until

1 December 2023

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis. This compliance statement has been revised, original issue date 28 November 2022.

Hørsholm, 28 November 2022

Lars Lindskov Pedersen

Test Manager

Dennis Andersen

Head of Department

