

Compliance Statement

No. 2023-259A

Data communication cable, Category 6A

Company

DataCom
3rd Floor S-19 Hotel Suites
Al Jaddaf Waterfront, P.O Box 24120,
Dubai, United Arab Emirates

Product description

Screened cable (F/FTP) characterised up to 500 MHz
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs with overall foil screen
Flame retardant, halogen free

Product identification

DATACOM CAT6A F/FTP 10G 4PAIR 23AWG CABLE (IEC 60332-1)-LSZH 305M
Part no.: DC-CBL-C6A-FF-LSZH

Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-10-1:2012
- TIA-568.2-D:2018

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12325291, DANAK-19/23397

EC Cabling product ID

6887


CS valid until

1 May 2024

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

This compliance statement has been revised, original issue date 25 April 2023.

Hørsholm, 11 April 2023


Lars Lindskov Pedersen
Test Manager


Dennis Andersen
Head of Department